


IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761 • Phone (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



CERTIFICATE OF LISTING



IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

Issued To:

CONTAINMENT SOLUTIONS INC.

500 CONROE PARK WEST DR. CONROE, TX 77303 , United States

Product:

Rainwater Harvesting Tanks

Products are in compliance with the following code(s):
Uniform Plumbing Code (UPC®)

Products are in compliance with the following standard(s)
IAPMO/ANSI Z1002-2020

File Number: 9898

Effective Date: July 2019

Void After: July 2024*


Chairman, Product Certification Committee





Chief Technical Service Officer

*This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: CONTAINMENT SOLUTIONS INC.

Effective Date: July 2019

File Number: 9898

Product: Rainwater Harvesting Tanks

Void After: July 2024

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Identification:

Each tank shall be clearly and permanently marked with the manufacturer's name and/or registered trademark, model or serial number, working liquid volume, date (i.e., month and year), date code or identifier traceable to the date of manufacture, maximum design load and maximum burial depth for which the tank is designed, when applicable. Accesses not suitable for human entry shall be mark with "DO NOT ENTER". Accesses intended for human entry shall be marked "CONFINED SPACE. FOLLOW APPROPRIATE PROCEDURES BEFORE ENTRY". Markings shall appear on permanently-affixed metal plates, etching, mechanical stamping, stamping with a permanent (non-water-soluble) ink, or molding in. Adhesive labels that comply with UL 969 shall also be considered permanent when placed on a surface that is not normally submerged in water. Permanent markings shall be adequately protected from corrosion so as to remain legible over the life of the tank. The product shall also bear the UPC® certification mark adjacent to product markings.

Rainwater harvesting tanks with liners shall also have markings indicating that the tank has a liner, the thickness of the liner, and the material of the liner.


Characteristics:

Rainwater harvesting tanks made of concrete, fiber-reinforced polyester, steel, thermoplastics, wood, or vinyl-coated polyester. To be installed in accordance with the manufacturer's instructions and the latest edition of the Uniform Plumbing Code.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: CONTAINMENT SOLUTIONS INC.

Effective Date: July 2019

File Number: 9898

Product: Rainwater Harvesting Tanks

Void After: July 2024


This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Models

Model Number	Description
SWT D-5 (4')	Tank Capacity (gal.) 1000
SWT D-5 (4')	Tank Capacity (gal.) 1500
SWT D-5 (4')	Tank Capacity (gal.) 2000
SWT D-6 (10')	Tank Capacity (gal.) 10000
SWT D-6 (10')	Tank Capacity (gal.) 12000
SWT D-6 (10')	Tank Capacity (gal.) 15000
SWT D-6 (10')	Tank Capacity (gal.) 20000
SWT D-6 (10')	Tank Capacity (gal.) 25000
SWT D-6 (10')	Tank Capacity (gal.) 30000
SWT D-6 (10')	Tank Capacity (gal.) 35000
SWT D-6 (10')	Tank Capacity (gal.) 40000
SWT D-6 (6')	Tank Capacity (gal.) 2000
SWT D-6 (6')	Tank Capacity (gal.) 2500
SWT D-6 (6')	Tank Capacity (gal.) 3000
SWT D-6 (6')	Tank Capacity (gal.) 4000
SWT D-6 (6')	Tank Capacity (gal.) 5000
SWT D-6 (6')	Tank Capacity (gal.) 6000
SWT D-7 (12")	Tank Capacity (gal.) 25000
SWT D-7 (12")	Tank Capacity (gal.) 30000
SWT D-7 (12")	Tank Capacity (gal.) 35000
SWT D-7 (12")	Tank Capacity (gal.) 40000
SWT D-7 (12")	Tank Capacity (gal.) 45000
SWT D-7 (12")	Tank Capacity (gal.) 48000
SWT D-7 (12")	Tank Capacity (gal.) 50000
SWT F-1 (12')	Tank Capacity (gal.) 25000
SWT F-1 (12')	Tank Capacity (gal.) 30000
SWT F-1 (12')	Tank Capacity (gal.) 35000

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: CONTAINMENT SOLUTIONS INC.

Effective Date: July 2019

File Number: 9898

Product: Rainwater Harvesting Tanks

Void After: July 2024

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Model Number	Description
SWT F-1 (12')	Tank Capacity (gal.) 40000
SWT F-1 (12')	Tank Capacity (gal.) 45000
SWT F-1 (12')	Tank Capacity (gal.) 48000
SWT F-1 (12')	Tank Capacity (gal.) 50000
SWT G-6 (8')	Tank Capacity (gal.) 4000
SWT G-6 (8')	Tank Capacity (gal.) 5000
SWT G-6 (8')	Tank Capacity (gal.) 6000
SWT G-6 (8')	Tank Capacity (gal.) 7000
SWT G-6 (8')	Tank Capacity (gal.) 8000
SWT G-6 (8')	Tank Capacity (gal.) 10000
SWT G-6 (8')	Tank Capacity (gal.) 12000
SWT G-6 (8')	Tank Capacity (gal.) 15000